

DMR Copy of Record

Permit			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	21 W 551 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
		Facility:	GWA CSO STORMWATER FACILITY
		Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148

Report Dates & Status			
Monitoring Period:	From 12/01/17 to 12/31/17	DMR Due Date:	01/25/18
		Status:	NetDMR Validated

Considerations for Form Completion
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer			
First Name:	matt	Title:	exective director
Last Name:	Streicher	Telephone:	630-790-1901

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type					
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample																	
					Permit Req.								Req Mon MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample																	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI						C - No Discharge					C - No Discharge						
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample																	
					Permit Req.									Req Mon MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample																	
					Permit Req.										Req Mon DAILY MX			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample																	
					Permit Req.								<=	.75 MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample																	
					Permit Req.										<=	400 DAILY MX			13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI																	
82220	Flow, total	1 - Effluent Gross	0	--	Sample																	
					Permit Req.																	
					Value NODI																	

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
GLENBARD WASTEWATER AUTHORITY

User: GOODALIS
Name: davod goodalis
E-Mail: dgoodalis@gbww.org
Date/Time: 2018-01-18 08:48 (Time Zone: -06:00)

Report Last Signed By

User: GOODALIS
Name: davod goodalis
E-Mail: dgoodalis@gbww.org
Date/Time: 2018-01-18 08:49 (Time Zone: -06:00)