

DMR Copy of Record

Permit																					
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY							Facility:	GWA CSO STORMWATER FACILITY										
Major:	No	Permittee Address:	21 W 551 BEMIS RD GLEN ELLYN, IL 60137							Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148										
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY																		
Report Dates & Status																					
Monitoring Period:	From 01/01/18 to 01/31/18							DMR Due Date:	02/25/18							Status:	NetDMR Validated				
Considerations for Form Completion																					
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:																					
Principal Executive Officer																					
First Name:	matt							Title:	executive director							Telephone:	630-790-1901				
Last Name:	streicher																				
No Data Indicator (NODI)																					
Form NODI:	--																				
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units						
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--						=		117.75			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
												Req Mon MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
00400	pH	1 - Effluent Gross	0	--					=	7.9			=	7.93	12 - SU		DL/DS - Daily When Discharging	GR - GRAB			
									>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB			
00530	Solids, total suspended	1 - Effluent Gross	0	--						=		87			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
												Req Mon MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--									=	1.43	19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
														Req Mon DAILY MX	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
50060	Chlorine, total residual	1 - Effluent Gross	0	--						=		0.01			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
										<=		.75 MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
74055	Coliform, fecal general	1 - Effluent Gross	0	--									=	0	13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB			
													<=	400 DAILY MX	13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB			
82220	Flow, total	1 - Effluent Gross	0	--			=	9.45	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN			
									Req Mon MO TOTAL	80 - Mgal/mo						0	DL/DS - Daily When Discharging	CN - CONTIN			
Submission Note																					
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																					
Edit Check Errors																					
No errors.																					
Comments																					
Attachments																					
No attachments.																					
Report Last Saved By																					
GLENBARD WASTEWATER AUTHORITY																					
User:	MSTREICHER																				
Name:	Matthew Streicher																				
E-Mail:	mstreicher@gbww.org																				
Date/Time:	2018-02-15 08:35 (Time Zone: -06:00)																				
Report Last Signed By																					
User:	MSTREICHER																				
Name:	Matthew Streicher																				
E-Mail:	mstreicher@gbww.org																				
Date/Time:	2018-02-15 08:35 (Time Zone: -06:00)																				