

DMR Copy of Record

Permit

Permit #:
Major:

IL0022471
No

Permittee:
Permittee Address:

GLENBARD WASTEWATER AUTHORITY
21 W 551 BEMIS RD
GLEN ELLYN, IL 60137

Facility:
Facility Location:

GWA CSO STORMWATER FACILITY
ILLINOIS ROUTE 53 AND HILL AVE
LOMBARD, IL 60148

Permitted Feature:

001
External Outfall

Discharge:

001-0
COMBINED SEWAGE TREATMENT FACILITY

Report Dates & Status

Monitoring Period:

From 10/01/17 to 10/31/17

DMR Due Date:

11/25/17

Status:

NetDMR Validated

Considerations for Form Completion

BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer

First Name:
Last Name:

Matt
Streicher

Title:

Asst. Director

Telephone:

630-790-1901

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading				Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample								=	65.1			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.									Req Mon MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7			=	7	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	26.5			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.									Req Mon MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample										=	0.7	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.											Req Mon DAILY MX	19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								=	0.05			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.								<=	.75 MO AVG			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
X 74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample										=	500	13 - #/100mL	2	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.										<=	400 DAILY MX	13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	84.6	80 - Mgal/mo								0	DL/DS - Daily When Discharging	CN - CONTIN
					Permit Req.				Req Mon MO TOTAL	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User:

GOODALIS

Name:

davod goodalis

E-Mail:

dgoodalis@gbww.org

Date/Time:

2017-11-14 09:44 (Time Zone: -06:00)

Report Last Signed By

User:

GOODALIS

Name:

davod goodalis

