

DMR Copy of Record

Permit

Permit #:
Major:

IL0021547
Yes

Permittee:
Permittee Address:

GLENBARD WASTEWATER AUTHORITY
21 W 551 BEMIS ROAD
GLEN ELLYN, IL 60137

Facility:
Facility Location:

GLENBARD WASTEWATER AUTHORITY - MAIN WWTP
21 W 551 BEMIS ROAD
GLEN ELLYN, IL 60137

Permitted Feature:

INF
Influent Structure

Discharge:

INF-L
INFLUENT MONITORING

Report Dates & Status

Monitoring Period:
From 10/01/17 to 10/31/17

DMR Due Date:
11/25/17

Status:
NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

MATT
STREICHER

Title:

ASST DIRECTOR

Telephone:

630-790-1901

No Data Indicator (NODI)

Form NODI:

--

Parameter	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample							=	182			19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.								Req Mon MO AVG			19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample							=	330			19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.								Req Mon MO AVG			19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI														
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample									=	12.5	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.										Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Value NODI														
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample									=	7.3	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.										Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	16.4	=	43.6	03 - MGD								99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User:
Name:
E-Mail:
Date/Time:

GOODALIS
davod goodalis
dgoodalis@gbww.org
2017-11-14 09:36 (Time Zone: -06:00)

Report Last Signed By

GLENBARD WASTEWATER AUTHORITY

User:
Name:
E-Mail:
Date/Time:

GOODALIS
davod goodalis
dgoodalis@gbww.org
2017-11-14 09:37 (Time Zone: -06:00)