

DMR Copy of Record

Permit																				
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY											Facility:	GWA CSO STORMWATER FACILITY					
Major:	No	Permittee Address:	21 W 551 BEMIS RD GLEN ELLYN, IL 60137											Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148					
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY																	
Report Dates & Status																				
Monitoring Period:	From 06/01/18 to 06/30/18		DMR Due Date:	07/25/18											Status:	NetDMR Validated				
Considerations for Form Completion																				
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:																				
Principal Executive Officer																				
First Name:	matt		Title:	executive director											Telephone:	630-790-1901				
Last Name:	streicher																			
No Data Indicator (NODI)																				
Form NODI:	--																			
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type				
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--						=		38.04			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
												Req Mon MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
00400	pH	1 - Effluent Gross	0	--					=	6.99			=	7.81	12 - SU		DL/DS - Daily When Discharging	GR - GRAB		
									>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB		
00530	Solids, total suspended	1 - Effluent Gross	0	--						=		29.6			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
												Req Mon MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--									=	0.75	19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
														Req Mon DAILY MX	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
50060	Chlorine, total residual	1 - Effluent Gross	0	--						=		0.02			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
										<=		.75 MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
74055	Coliform, fecal general	1 - Effluent Gross	0	--									=	8	13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB		
													<=	400 DAILY MX	13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB		
82220	Flow, total	1 - Effluent Gross	0	--			=	77.18	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN		
								Req Mon MO TOTAL	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN		
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
Attachments																				
No attachments.																				
Report Last Saved By																				
GLENBARD WASTEWATER AUTHORITY																				
User:	MSTREICHER																			
Name:	Matthew Streicher																			
E-Mail:	mstreicher@gbww.org																			
Date/Time:	2018-07-24 09:01 (Time Zone: -05:00)																			
Report Last Signed By																				
User:	MSTREICHER																			
Name:	Matthew Streicher																			
E-Mail:	mstreicher@gbww.org																			
Date/Time:	2018-07-24 09:01 (Time Zone: -05:00)																			