

## DMR Copy of Record

Permit																						
Permit #:		IL0022471		Permittee:		GLENBARD WASTEWATER AUTHORITY				Facility:		GWA CSO STORMWATER FACILITY										
Major:		No		Permittee Address:		21 W 551 BEMIS RD GLEN ELLYN, IL 60137				Facility Location:		ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148										
Permitted Feature:		001 External Outfall		Discharge:		001-0 COMBINED SEWAGE TREATMENT FACILITY																
Report Dates & Status																						
Monitoring Period:				From 08/01/18 to 08/31/18				DMR Due Date:				09/25/18				Status:			NetDMR Validated			
Considerations for Form Completion																						
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:																						
Principal Executive Officer																						
First Name:				matt				Title:				executive director				Telephone:			630-710-1901			
Last Name:				stricher																		
No Data Indicator (NODI)																						
Form NODI: --																						
Table Headers																						
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	78.7			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.										19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB				
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.1			=	7.1	12 - SU		DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	13			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.										19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB				
					Value NODI																	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	0.77			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.										19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB				
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	0			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.						<=	.75 MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB				
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample									=	0	13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.									<=	400 DAILY MX	13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	2.22	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN			
					Permit Req.				Req Mon MO TOTAL	80 - Mgal/mo							0	DL/DS - Daily When Discharging	CN - CONTIN			
					Value NODI																	
Submission Note																						
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																						
Edit Check Errors																						
No errors.																						
Comments																						
Attachments																						
No attachments.																						
Report Last Saved By																						
GLENBARD WASTEWATER AUTHORITY																						
User:				PETERSDAVID																		
Name:				David Peters																		
E-Mail:				dpeters@gbww.org																		
Date/Time:				2018-09-18 09:44 (Time Zone: -05:00)																		
Report Last Signed By																						
User:				PETERSDAVID																		
Name:				David Peters																		
E-Mail:				dpeters@gbww.org																		
Date/Time:				2018-09-18 09:44 (Time Zone: -05:00)																		