

DMR Copy of Record

Permit			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	21 W 551 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		
Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148		

Report Dates & Status			
Monitoring Period:	From 10/01/18 to 10/31/18	DMR Due Date:	11/25/18
Status:	NetDMR Validated		

Considerations for Form Completion
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample					=	84.4					19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.										19 - mg/L				
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.1				12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM				12 - SU
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	60				19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										19 - mg/L				
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	0.99				19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										19 - mg/L				
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	0				19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					<=	.75 MO AVG				19 - mg/L				
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample					=	0				13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										13 - #/100mL				
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	3.02					80 - Mgal/mo	0	DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.													80 - Mgal/mo	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
GLENBARD WASTEWATER AUTHORITY

User: MSTREICHER
Name: Matthew Streicher
E-Mail: mstreicher@gbww.org
Date/Time: 2018-11-15 08:35 (Time Zone: -06:00)

Report Last Signed By
User: MSTREICHER
Name: Matthew Streicher
E-Mail: mstreicher@gbww.org
Date/Time: 2018-11-15 08:35 (Time Zone: -06:00)