

DMR Copy of Record

Permit																						
Permit #:	IL0021547	Permittee:	GLENBARD WASTEWATER AUTHORITY							Facility:	GLENBARD WASTEWATER AUTHORITY - MAIN WWTP											
Major:	Yes	Permittee Address:	945 BEMIS ROAD GLEN ELLYN, IL 60137							Facility Location:	945 BEMIS ROAD GLEN ELLYN, IL 60137											
Permitted Feature:	INF Influent Structure	Discharge:	INF-L INFLUENT MONITORING																			
Report Dates & Status																						
Monitoring Period:	From 03/01/19 to 03/31/19		DMR Due Date:	04/25/19							Status:	NetDMR Validated										
Considerations for Form Completion																						
Principal Executive Officer																						
First Name:	matt		Title:	exective director							Telephone:	630-790-1901										
Last Name:	streicher																					
No Data Indicator (NODI)																						
Form NODI:	--																					
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units						
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample						=		148.25			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS				
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS				
					Value NODI																	
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=		201			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS				
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS				
					Value NODI																	
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample									=	34.6	19 - mg/L	01/30 - Monthly	CP - COMPOS				
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS				
					Value NODI																	
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample									=	7.25	19 - mg/L	01/30 - Monthly	CP - COMPOS				
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS				
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	14.28	=	28.28	03 - MGD							99/99 - Continuous					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous					
					Value NODI																	
Submission Note																						
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																						
Edit Check Errors																						
No errors.																						
Comments																						
This form has been updated as it was completed last month, before the end of the monitoring period.																						
Attachments																						
No attachments.																						
Report Last Saved By																						
GLENBARD WASTEWATER AUTHORITY																						
User:	TOMROMZA																					
Name:	Thomas Romza																					
E-Mail:	tromza@gbww.org																					
Date/Time:	2019-04-18 08:13 (Time Zone: -05:00)																					
Report Last Signed By																						
User:	TOMROMZA																					
Name:	Thomas Romza																					
E-Mail:	tromza@gbww.org																					
Date/Time:	2019-04-18 08:13 (Time Zone: -05:00)																					