

DMR Copy of Record

Permit

Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY						Facility:	GWA CSO STORMWATER FACILITY					
Major:	No	Permittee Address:	21 W 551 BEMIS RD GLEN ELLYN, IL 60137						Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148					
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY												

Report Dates & Status

Monitoring Period:	From 05/01/19 to 05/31/19	DMR Due Date:	06/25/19						Status:	NetDMR Validated					
--------------------	---------------------------	---------------	----------	--	--	--	--	--	---------	------------------	--	--	--	--	--

Considerations for Form Completion

BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer

First Name:	Matthew	Title:	Executive Director						Telephone:	630-790-1901					
Last Name:	Streicher														

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type		
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample								=	56.97			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.											Req Mon MO AVG	19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.22			=	7.83	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	28.78			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.												Req Mon MO AVG		19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI																	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample										=	0.62	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.												Req Mon DAILY MX		19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								=	0.04			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.												.75 MO AVG		19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample										=	88	13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.												<=		400 DAILY MX	13 - #/100mL	DL/DS - Daily When Discharging	GR - GRAB
					Value NODI																	
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	179.06	80 - Mgal/mo								0	DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.				Req Mon MO TOTAL	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN		
					Value NODI																	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: MSTREICHER

Name: Matthew Streicher

E-Mail: mstreicher@gbww.org

Date/Time: 2019-06-17 11:11 (Time Zone: -05:00)

Report Last Signed By

User: MSTREICHER

Name: Matthew Streicher

E-Mail: mstreicher@gbww.org

Date/Time: 2019-06-17 11:11 (Time Zone: -05:00)