

DMR Copy of Record

Permit																					
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY												Facility:	GWA CSO STORMWATER FACILITY					
Major:	No	Permittee Address:	954 BEMIS RD GLEN ELLYN, IL 60137												Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148					
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY																		
Report Dates & Status																					
Monitoring Period:	From 10/01/19 to 10/31/19						DMR Due Date:	11/25/19						Status:	NetDMR Validated						
Considerations for Form Completion																					
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:																					
Principal Executive Officer																					
First Name:	Matt						Title:	Executive Director						Telephone:	630-790-1901						
Last Name:	Streicher																				
No Data Indicator (NODI)																					
Form NODI:	--																				
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units						
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--						=		48.88			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
																0	DL/DS - Daily When Discharging	GR - GRAB			
00400	pH	1 - Effluent Gross	0	--					=	7.6			=	7.86	12 - SU		DL/DS - Daily When Discharging	GR - GRAB			
									>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB			
00530	Solids, total suspended	1 - Effluent Gross	0	--						=		15.5			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
																0	DL/DS - Daily When Discharging	GR - GRAB			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--									=	0.51	19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
																0	DL/DS - Daily When Discharging	GR - GRAB			
50060	Chlorine, total residual	1 - Effluent Gross	0	--						=		0.04			19 - mg/L		DL/DS - Daily When Discharging	GR - GRAB			
										<=		.75 MO AVG			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
74055	Coliform, fecal general	1 - Effluent Gross	0	--									=	0	13 - #/100mL		DL/DS - Daily When Discharging	GR - GRAB			
													<=	400 DAILY MX	13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB			
82220	Flow, total	1 - Effluent Gross	0	--			=	60.98	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN			
																0	DL/DS - Daily When Discharging	CN - CONTIN			
Submission Note																					
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																					
Edit Check Errors																					
No errors.																					
Comments																					
Attachments																					
No attachments.																					
Report Last Saved By																					
GLENBARD WASTEWATER AUTHORITY																					
User:	PETERSDAVID																				
Name:	David Peters																				
E-Mail:	dpeters@gbww.org																				
Date/Time:	2019-11-21 07:40 (Time Zone: -06:00)																				
Report Last Signed By																					
User:	PETERSDAVID																				
Name:	David Peters																				
E-Mail:	dpeters@gbww.org																				
Date/Time:	2019-11-21 07:40 (Time Zone: -06:00)																				