

DMR Copy of Record

Permit			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	954 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		
Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148		

Report Dates & Status			
Monitoring Period:	From 11/01/20 to 11/30/20	DMR Due Date:	12/25/20
Status:	NetDMR Validated		

Considerations for Form Completion
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample														
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI						C - No Discharge				C - No Discharge				
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
0

Attachments
No attachments.

Report Last Saved By
GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2020-12-14 12:21 (Time Zone: -06:00)

Report Last Signed By
User: PETERSDAVID

Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2020-12-14 12:22 (Time Zone: -06:00)