

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	954 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		
Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148		

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 01/01/21 to 01/31/21	DMR Due Date:	02/25/21
Status:	NetDMR Validated		

**Considerations for Form Completion**  
 BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

<b>Principal Executive Officer</b>			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample												19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.														
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						>=	6.0 MINIMUM		<=	9.0 MAXIMUM	12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.						<=	0.75 MO AVG							
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample											13 - #/100mL	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample											80 - Mgal/mo	DL/DS - Daily When Discharging	CN - CONTIN	
					Permit Req.														
					Value NODI														

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**

**Attachments**  
 No attachments.

**Report Last Saved By**  
 GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID  
 Name: David Peters  
 E-Mail: dpeters@gbww.org  
 Date/Time: 2021-02-10 12:43 (Time Zone: -06:00)

**Report Last Signed By**  
 User: PETERSDAVID

Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2021-02-10 12:44 (Time Zone: -06:00)