

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample = 12.32 = 24.37 03 - MGD													99/99 - Continuous
					Permit Req. Req Mon MO AVG													99/99 - Continuous
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample = 0.0 19 - mg/L													CL/OC - Chlorination/Occurances GR - GRAB
					Permit Req. <= 0.05 DAILY MX 19 - mg/L													CL/OC - Chlorination/Occurances GR - GRAB
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 192.51 = 338.92 26 - lb/d													02/DA - 2 Days Every Week CP - COMPOS
					Permit Req. <= 3920.0 MO AVG <= 7840.0 DAILY MX 26 - lb/d													02/DA - 2 Days Every Week CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2021-04-08 13:15 (Time Zone: -05:00)

Report Last Signed By

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2021-04-08 13:16 (Time Zone: -05:00)