

50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample	=	0.0	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB							
					Permit Req.	<=	0.05 DAILY MX	19 - mg/L		CL/OC - Chlorination/Occurances	GR - GRAB							
					Value NODI													
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample	=	0.0	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - GRAB							
					Permit Req.	<=	400.0 DAILY MX	13 - #/100mL		02/DA - 2 Days Every Week	GR - GRAB							
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	181.14	=	424.91	26 - lb/d	=	2.44	=	5.1	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d	<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2021-08-10 13:41 (Time Zone: -05:00)

Report Last Signed By

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2021-08-10 13:42 (Time Zone: -05:00)