



50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample							=	0.0	19 - mg/L		CL/OC - Chlorination/Occurances	GR - GRAB		
					Permit Req.							<=	0.05 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB		
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	135.06	=	247.1	26 - lb/d		=	1.91	=	3.6	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d		<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**GLENBARD WASTEWATER AUTHORITY**

User: PETERSDAVID  
Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2021-12-08 13:15 (Time Zone: -06:00)

**Report Last Signed By**

User: PETERSDAVID  
Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2021-12-08 13:16 (Time Zone: -06:00)