

50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample	=		=		=		=	0.0	19 - mg/L	CL/OC - Chlorination/Occurances GR - GRAB			
					Permit Req.	<=		<=	0.05 DAILY MX	<=		<=		19 - mg/L	CL/OC - Chlorination/Occurances GR - GRAB			
					Value NODI									0				
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	162.01	=	238.89	=	26 - lb/d	=	2.1	=	3.1	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	<=	26 - lb/d	<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2022-01-13 12:44 (Time Zone: -06:00)

Report Last Signed By

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2022-01-13 12:44 (Time Zone: -06:00)