

| | | | | | | | | | | | | | | | | | | | | | | | |
|-------|---------------------------------|--------------------|---|----|-------------|----|---------------|----|-----------------|-----------|--|--|--|----|-------------|-----------|---------------------------------|-----------|---------------------------|---------------------------|-------------|---------------------------------|-----------|
| 50060 | Chlorine, total residual | 1 - Effluent Gross | 0 | -- | Sample | | | | | | | | | = | 0.0 | 19 - mg/L | CL/OC - Chlorination/Occurances | GR - GRAB | | | | | |
| | | | | | Permit Req. | | | | | | | | | | | | | <= | 0.05 DAILY MX | 19 - mg/L | 0 | CL/OC - Chlorination/Occurances | GR - GRAB |
| | | | | | Value NODI | | | | | | | | | | | | | | | | | | |
| 80082 | BOD, carbonaceous [5 day, 20 C] | 1 - Effluent Gross | 0 | -- | Sample | = | 167.04 | = | 307.3 | 26 - lb/d | | | | = | 2.44 | = | 4.6 | 19 - mg/L | 02/DA - 2 Days Every Week | CP - COMPOS | | | |
| | | | | | Permit Req. | <= | 3920.0 MO AVG | <= | 7840.0 DAILY MX | 26 - lb/d | | | | <= | 10.0 MO AVG | <= | 20.0 DAILY MX | 19 - mg/L | 0 | 02/DA - 2 Days Every Week | CP - COMPOS | | |
| | | | | | Value NODI | | | | | | | | | | | | | | | | | | |

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2022-02-08 12:55 (Time Zone: -06:00)

Report Last Signed By

User: PETERSDAVID
Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2022-02-08 12:56 (Time Zone: -06:00)