

50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample	=		=		=	0.0	19 - mg/L		CL/OC - Chlorination/Occurances	GR - GRAB			
					Permit Req.	<=		<=	0.038 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB					
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	258.25	=	393.81	=	26 - lb/d	=	1.79	=	2.0	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d	<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2022-05-16 13:26 (Time Zone: -05:00)

Report Last Signed By

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2022-05-16 13:26 (Time Zone: -05:00)