

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	945 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		
Facility Location:	ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148		

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 12/01/22 to 12/31/22	DMR Due Date:	01/25/23
Status:	NetDMR Validated		

**Considerations for Form Completion**  
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

<b>Principal Executive Officer</b>			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

**No Data Indicator (NODI)**

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	99.6				19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.						Req Mon MO AVG				19 - mg/L				
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.39			12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM				12 - SU
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	30.0			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.						Req Mon MO AVG				19 - mg/L				
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	0.66			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.						Req Mon DAILY MX				19 - mg/L				
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	0.08			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					<=	0.75 MO AVG				19 - mg/L				
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	4.0			13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.						<=	400.0 DAILY MX							13 - #/100mL
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	6.86	80 - Mgal/mo					0	DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.				Req Mon MO TOTAL	80 - Mgal/mo									
					Value NODI														

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**  
No attachments.

**Report Last Saved By**  
GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID  
Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2023-01-09 14:04 (Time Zone: -06:00)

**Report Last Signed By**  
User: PETERSDAVID

Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2023-01-09 14:04 (Time Zone: -06:00)