



50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample	=		=		=		=	0.0	19 - mg/L	CL/OC - Chlorination/Occurances GR - GRAB			
					Permit Req.	<=		<=	0.038 DAILY MX	<=		<=		19 - mg/L	CL/OC - Chlorination/Occurances GR - GRAB			
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	155.78	=	248.25	=	26 - lb/d	=	2.31	=	3.3	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	<=	26 - lb/d	<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI											0		

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**GLENBARD WASTEWATER AUTHORITY**

User: PETERSDAVID  
Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2023-01-11 12:32 (Time Zone: -06:00)

**Report Last Signed By**

User: PETERSDAVID  
Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2023-01-11 12:32 (Time Zone: -06:00)