

DMR Copy of Record

Permit

Permit #:
Major:

IL0021547
Yes

Permittee:
Permittee Address:

GLENBARD WASTEWATER AUTHORITY
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Facility:
Facility Location:

GLENBARD WASTEWATER AUTHORITY - MAIN WWTP
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Permitted Feature:

001
External Outfall

Discharge:

001-0
STP OUTFALL

Report Dates & Status

Monitoring Period:
From 01/01/23 to 01/31/23

DMR Due Date:
02/25/23

Status:
NetDMR Validated

Considerations for Form Completion

W0430600002 ; DMF LOAD LIMITS DISPLAYED.

Principal Executive Officer

First Name:
Last Name:

Matt
Streicher

Title:

Executive Director

Telephone:

630-790-1901

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00011	Temperature, water deg. fahrenheit	1 - Effluent Gross	0	--	Sample											56.8	15 - deg F	0	01/30 - Monthly	GR - GRAB
					Permit Req.											Req Mon MO MAX	15 - deg F		01/30 - Monthly	GR - GRAB
					Value NODI															
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	1	--	Sample						=	10.06	=	10.09	=	9.63	19 - mg/L	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.						>=	5.5 MO AV MN	>=	4.0 MN WK AV	>=	3.5 DAILY MN	19 - mg/L		02/DA - 2 Days Every Week	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.43			=	7.98	12 - SU	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		02/DA - 2 Days Every Week	GR - GRAB
					Value NODI															
00410	Alkalinity, total [as CaCO3]	1 - Effluent Gross	0	--	Sample										=	124.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	426.93	=	1140.41	26 - lb/d			=	4.32	=	6.0	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	4704.0 MO AVG	<=	9408.0 DAILY MX	26 - lb/d			<=	12.0 MO AVG	<=	24.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample										=	14.2	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	4.29	=	17.11	26 - lb/d			=	0.03	=	0.09	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	1294.0 MO AVG	<=	2940.0 DAILY MX	26 - lb/d			<=	3.3 MO AVG	<=	7.5 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample										=	1.6	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample										=	12.6	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample							=	2.7	=	2.92	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.								Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample										=	2.6	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample										=	178.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	10.97	=	22.79	03 - MGD								0	99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	
					Value NODI															

50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample										=	0.0	19 - mg/L	0	CL/OC - Chlorination/Occurrences	GR - GRAB		
					Permit Req.												<=		0.038 DAILY MX	19 - mg/L	CL/OC - Chlorination/Occurrences	GR - GRAB
					Value NODI																	

80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	232.37	=	912.33	26 - lb/d			=	2.02	=	4.8	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d			<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User:

PETERSDAVID

Name:

David Peters

E-Mail:

dpeters@gbww.org

Date/Time:

2023-02-08 13:13 (Time Zone: -06:00)

Report Last Signed By

User:

PETERSDAVID

Name:

David Peters

E-Mail:

dpeters@gbww.org

Date/Time:

2023-02-08 13:13 (Time Zone: -06:00)