

DMR Copy of Record

Permit			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	945 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		Facility Location:
		ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148	

Report Dates & Status			
Monitoring Period:	From 09/01/23 to 09/30/23	DMR Due Date:	10/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
 BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

Principal Executive Officer			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	112.5			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.										Req Mon MO AVG				19 - mg/L	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	8.64			=	8.67	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU				
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	47.0			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.													Req Mon MO AVG	19 - mg/L	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	0.95			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.													Req Mon DAILY MX	19 - mg/L	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	0.02			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.						<=	0.75 MO AVG						19 - mg/L		
					Value NODI															
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample					=	0.0			13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB			
					Permit Req.													<=	400.0 DAILY MX	13 - #/100mL
					Value NODI															
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	2.58	80 - Mgal/mo						0	DL/DS - Daily When Discharging	CN - CONTIN			
					Permit Req.			Req Mon MO TOTAL	80 - Mgal/mo											
					Value NODI															

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
 GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2023-10-10 12:10 (Time Zone: -05:00)

Report Last Signed By
 User: PETERSDAVID

Name: David Peters
E-Mail: dpeters@gbww.org
Date/Time: 2023-10-10 12:11 (Time Zone: -05:00)