

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:
Major:

IL0021547
Yes

Permittee:
Permittee Address:

GLENBARD WASTEWATER AUTHORITY
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Facility:
Facility Location:

GLENBARD WASTEWATER AUTHORITY - MAIN WWTP
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Permitted Feature:

001
External Outfall

Discharge:

001-0
STP OUTFALL

Report Dates & Status

Monitoring Period:

From 10/01/25 to 10/31/25

DMR Due Date:

11/25/25

Status:

NetDMR Validated

Considerations for Form Completion

W0430600002 ; DMF LOAD LIMITS DISPLAYED.

Principal Executive Officer

First Name:
Last Name:

Matt
Streicher

Title:

Executive Director

Telephone:

630-790-1901

No Data Indicator (NODI)

Form NODI: --

Code	Parameter	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration								# of Ex.	Frequency of Analysis	Sample Type	
	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
00011	Temperature, water deg. fahrenheit	1 - Effluent Gross	0	--	Sample										=	72.3	15 - deg F	0	01/30 - Monthly	GR - Grab		
					Permit Req.											Req Mon MO MAX	15 - deg F		01/30 - Monthly	GR - Grab		
					Value NODI																	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	1	--	Sample						=	8.65			=	8.2	=	8.06	19 - mg/L	0	02/DA - 2 Days Every Week	GR - Grab
					Permit Req.						>=	5.5 MO AV MN			>=	4.0 MN WK AV	>=	3.5 DAILY MN	19 - mg/L		02/DA - 2 Days Every Week	GR - Grab
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.06				=	7.09	12 - SU	0	02/DA - 2 Days Every Week	GR - Grab	
					Permit Req.						>=	6.0 MINIMUM				<=	9.0 MAXIMUM	12 - SU		02/DA - 2 Days Every Week	GR - Grab	
					Value NODI																	
00410	Alkalinity, total [as CaCO3]	1 - Effluent Gross	0	--	Sample											=	50.0	19 - mg/L	0	01/30 - Monthly	GR - Grab	
					Permit Req.											Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	GR - Grab			
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	337.63	=	948.34	26 - lb/d			=	4.51	=	7.2	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite		
					Permit Req.	<=	4704.0 MO AVG	<=	9408.0 DAILY MX	26 - lb/d			<=	12.0 MO AVG	<=	24.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - Composite		
					Value NODI																	
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample											=	37.3	19 - mg/L	0	01/30 - Monthly	CP - Composite	
					Permit Req.											Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - Composite			
					Value NODI																	
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	11.47	=	62.76	26 - lb/d			=	0.13	=	0.45	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite		
					Permit Req.	<=	588.0 MO AVG	<=	1176.0 DAILY MX	26 - lb/d			<=	1.5 MO AVG	<=	3.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - Composite		
					Value NODI																	

00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample												Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite	
					Permit Req.																	
					Value NODI												B - Below Detection Limit/No Detection					
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample										=	37.3	19 - mg/L	0	01/30 - Monthly	CP - Composite		
					Permit Req.												Req Mon DAILY MX				19 - mg/L	
					Value NODI																	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample									=	4.04	=	5.66	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.											Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L				
					Value NODI																	
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample										=	5.66	19 - mg/L	0	01/30 - Monthly	CP - Composite		
					Permit Req.											Req Mon DAILY MX	19 - mg/L					
					Value NODI																	
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample										=	106.0	19 - mg/L	0	01/30 - Monthly	GR - Grab		
					Permit Req.												Req Mon DAILY MX				19 - mg/L	
					Value NODI																	
30500	Coliform, fecal - % samples exceeding limit	1 - Effluent Gross	0	--	Sample										=	0.0	23 - %	0	02/DA - 2 Days Every Week	GR - Grab		
					Permit Req.												<=				10.0 MAXIMUM	23 - %
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	7.82	=	16.72	03 - MGD								0	99/99 - Continuous			
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD												
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample										=	0.0	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - Grab		
					Permit Req.											<=	0.038 DAILY MX				19 - mg/L	
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample									=	6.37	=	245.0	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - Grab	
					Permit Req.											<=	200.0 GEO MEAN	Req Mon DAILY MX				13 - #/100mL
					Value NODI																	
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	251.11	=	557.85	26 - lb/d				=	3.49	=	5.4	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite	
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d				<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L				
					Value NODI																	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User:

MAMCGRATH

Name:

Micaela McGrath

E-Mail:

mmcgrath@gbww.org

Date/Time:

2025-11-21 06:40 (Time Zone: -06:00)

Report Last Signed By

User:

MAMCGRATH

