

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

[illegible]

00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite	
					Value NODI											B - Below Detection Limit/No Detection					
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample										=	49.3	19 - mg/L	0	01/30 - Monthly	CP - Composite	
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite	
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	4.28	=	4.92	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX		19 - mg/L	01/07 - Weekly	CP - Composite
					Value NODI																
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample										=	4.21	19 - mg/L	0	01/30 - Monthly	CP - Composite	
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite	
					Value NODI																
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample										=	100.0	19 - mg/L	0	01/30 - Monthly	GR - Grab	
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	GR - Grab	
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	7.59	=	11.22	03 - MGD								0	99/99 - Continuous		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous		
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample										=	0.0	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - Grab	
					Permit Req.										<=	0.038 DAILY MX	19 - mg/L		CL/OC - Chlorination/Occurances	GR - Grab	
					Value NODI																
X 80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	329.61	>	729.84	26 - lb/d				=	4.8	>	9.2	19 - mg/L	2	02/DA - 2 Days Every Week	CP - Composite
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d				<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - Composite
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

CBOD: There appeared to be an illicit discharge that came into the plant, and the effluent was not diluted enough to capture the higher value.

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: MAMCGRATH

Name: Micaela McGrath

E-Mail: mmcgrath@gbww.org

Date/Time: 2025-12-19 10:00 (Time Zone: -06:00)

Report Last Signed By

User: MAMCGRATH

Name: Micaela McGrath

E-Mail: mmcgrath@gbww.org

Date/Time: 2025-12-19 10:00 (Time Zone: -06:00)