

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit																				
Permit #:		IL0021547		Permittee:		GLENBARD WASTEWATER AUTHORITY				Facility:		GLENBARD WASTEWATER AUTHORITY - MAIN WWTP								
Major:		Yes		Permittee Address:		945 BEMIS ROAD GLEN ELLYN, IL 60137				Facility Location:		945 BEMIS ROAD GLEN ELLYN, IL 60137								
Permitted Feature:		001 External Outfall		Discharge:		001-0 STP OUTFALL														
Report Dates & Status																				
Monitoring Period:		From 01/01/26 to 01/31/26				DMR Due Date:		02/25/26				Status:		NetDMR Validated						
Considerations for Form Completion																				
W0430600002 ; DMF LOAD LIMITS DISPLAYED.																				
Principal Executive Officer																				
First Name:		Matt		Title:		Executive Director				Telephone:		630-790-1901								
Last Name:		Streicher																		
No Data Indicator (NODI)																				
Form NODI:		--																		
Table Headers																				
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00011	Temperature, water deg. fahrenheit	1 - Effluent Gross	0	--	Sample						=	56.1					15 - deg F	0	01/30 - Monthly	GR - Grab
					Permit Req.							Req Mon MO MAX				15 - deg F				
					Value NODI															
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	1	--	Sample						=	12.02	=	10.44	=	10.14	19 - mg/L	0	02/DA - 2 Days Every Week	GR - Grab
					Permit Req.						>=	5.5 MO AV MN	>=	4.0 MN WK AV	>=	3.5 DAILY MN	19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.6			=	7.1	12 - SU	0	02/DA - 2 Days Every Week	GR - Grab
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI															
00410	Alkalinity, total [as CaCO3]	1 - Effluent Gross	0	--	Sample										=	104.0	19 - mg/L	0	01/30 - Monthly	GR - Grab
					Permit Req.											Req Mon DAILY MX	19 - mg/L			
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	664.23	=	954.3	26 - lb/d		=	7.69	=	11.76	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite	
					Permit Req.	<=	4704.0 MO AVG	<=	9408.0 DAILY MX	26 - lb/d		<=	12.0 MO AVG	<=	24.0 DAILY MX	19 - mg/L				
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample										=	26.6	19 - mg/L	0	01/30 - Monthly	CP - Composite
					Permit Req.											Req Mon DAILY MX	19 - mg/L			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	8.16	=	39.59	26 - lb/d		=	0.07	=	0.27	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite	
					Permit Req.	<=	1294.0 MO AVG	<=	2940.0 DAILY MX	26 - lb/d		<=	3.3 MO AVG	<=	7.5 DAILY MX	19 - mg/L				
					Value NODI															
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample												0	01/30 - Monthly	CP - Composite	
					Permit Req.											Req Mon DAILY MX				19 - mg/L
					Value NODI															B - Below Detection Limit/No Detection
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample										=	26.6	19 - mg/L	0	01/30 - Monthly	CP - Composite
					Permit Req.											Req Mon DAILY MX	19 - mg/L			
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample										=	2.91	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.											Req Mon MO AVG	19 - mg/L			
					Value NODI												Req Mon DAILY MX			

					Value NODI															
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample = 2.69															
					Permit Req. Req Mon DAILY MX															
					Value NODI															
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample = 205.0															
					Permit Req. Req Mon DAILY MX															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample = 11.39	= 26.52	03 - MGD													
					Permit Req. Req Mon MO AVG	Req Mon DAILY MX	03 - MGD													
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample = 0.0															
					Permit Req. <= 0.038 DAILY MX															
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 608.99	= 1275.55	26 - lb/d													
					Permit Req. <= 3920.0 MO AVG	<= 7840.0 DAILY MX	26 - lb/d													
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: MAMCGRATH
 Name: Micaela McGrath
 E-Mail: mmcgrath@gbww.org
 Date/Time: 2026-02-12 13:05 (Time Zone: -06:00)

Report Last Signed By

User: MAMCGRATH
 Name: Micaela McGrath
 E-Mail: mmcgrath@gbww.org
 Date/Time: 2026-02-12 13:06 (Time Zone: -06:00)