

00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Permit Req.													Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - Composite		
					Value NODI													B - Below Detection Limit/No Detection					
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample													= 30.6	19 - mg/L	01/30 - Monthly	CP - Composite		
					Permit Req.													Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - Composite	
					Value NODI																		
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample													= 4.14	19 - mg/L	01/07 - Weekly	CP - Composite		
					Permit Req.													Req Mon MO AVG	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Value NODI																		
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample													= 3.43	19 - mg/L	01/30 - Monthly	CP - Composite		
					Permit Req.													Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - Composite	
					Value NODI																		
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample													= 195.0	19 - mg/L	01/30 - Monthly	GR - Grab		
					Permit Req.													Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	GR - Grab	
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	= 7.48		= 8.34	03 - MGD												99/99 - Continuous		
					Permit Req.	Req Mon MO AVG		Req Mon DAILY MX	03 - MGD												0	99/99 - Continuous	
					Value NODI																		
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample													= 0.0	19 - mg/L		CL/OC - Chlorination/Occurances	GR - Grab	
					Permit Req.													<= 0.038 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - Grab	
					Value NODI																		
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	= 466.3		= 1078.61	26 - lb/d									= 7.6	19 - mg/L		02/DA - 2 Days Every Week	CP - Composite	
					Permit Req.	<= 3920.0 MO AVG		<= 7840.0 DAILY MX	26 - lb/d									<= 10.0 MO AVG	19 - mg/L	0	<= 20.0 DAILY MX	02/DA - 2 Days Every Week	CP - Composite
					Value NODI																		

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Effluent TSS was high due to a combination of construction activity and biological complications.

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: MAMCGRATH
 Name: Micaela McGrath
 E-Mail: mmcgrath@gbww.org
 Date/Time: 2026-03-19 08:56 (Time Zone: -05:00)

Report Last Signed By

User: MAMCGRATH
 Name: Micaela McGrath
 E-Mail: mmcgrath@gbww.org
 Date/Time: 2026-03-19 08:56 (Time Zone: -05:00)