

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit		Permit #: IL0022471		Permittee: GLENBARD WASTEWATER AUTHORITY		Facility: GWA CSO STORMWATER FACILITY															
Major: No		Permittee Address: 945 BEMIS RD GLEN ELLYN, IL 60137		Facility Location: ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148																	
Permitted Feature: 001 External Outfall		Discharge: 001-0 COMBINED SEWAGE TREATMENT FACILITY																			
Report Dates & Status																					
Monitoring Period: From 03/01/26 to 03/31/26		DMR Due Date: 04/25/26		Status: NetDMR Validated																	
Considerations for Form Completion																					
BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:																					
Principal Executive Officer																					
First Name: Matt		Title: Executive Director		Telephone: 630-790-1901																	
Last Name: Streicher																					
No Data Indicator (NODI)																					
Form NODI: --																					
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units		
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	14.07				19 - mg/L	0	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.											19 - mg/L		DL/DS - Daily When Discharging	GR - Grab		
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.83			=	7.98	12 - SU	0	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		DL/DS - Daily When Discharging	GR - Grab		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	25.0				19 - mg/L	0	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.											19 - mg/L		DL/DS - Daily When Discharging	GR - Grab		
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample									=	0.38	19 - mg/L	0	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.													19 - mg/L	DL/DS - Daily When Discharging	GR - Grab	
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample									=	0.26	19 - mg/L	0	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.														19 - mg/L	DL/DS - Daily When Discharging	GR - Grab
					Value NODI																
X 74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample									=	850.0	13 - #/100mL	1	DL/DS - Daily When Discharging	GR - Grab		
					Permit Req.														13 - #/100mL	DL/DS - Daily When Discharging	GR - Grab
					Value NODI																
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	51.8	80 - Mgal/mo								0	DL/DS - Daily When Discharging	CN - Continuous		
					Permit Req.															DL/DS - Daily When Discharging	CN - Continuous
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

of Events: 3 During sample collection on 3/10, the operator discovered that the thio line was broken. To ensure compliance with the 0.75 mg/L chlorine residual permit limit, the operator reduced the hypo feed. This adjustment successfully kept the chlorine residual below the permit threshold at the time the sample was collected. However, the reduced hypo dosage resulted in an elevated fecal coliform count in the sample.

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: MAMCGRATH
Name: Micaela McGrath
E-Mail: mmcgrath@gbww.org
Date/Time: 2026-04-23 13:32 (Time Zone: -05:00)

Report Last Signed By

User: MAMCGRATH
Name: Micaela McGrath
E-Mail: mmcgrath@gbww.org
Date/Time: 2026-04-23 13:32 (Time Zone: -05:00)