



00610	Nitrogen, ammonia total [as N]	8 - Other Treatment, Process Complete	0	--	Sample	=	35.35	=	26 - lb/d	=	0.25	19 - mg/L	02/DA - 2 Days Every Week	CP - Composite					
					Permit Req.	<=	2469.0 WKLY AVG	<=	26 - lb/d	<=	6.3 WKLY AVG	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite				
					Value NODI														
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample							19 - mg/L	01/30 - Monthly	CP - Composite					
					Permit Req.							Req Mon DAILY MX							
					Value NODI							B - Below Detection Limit/No Detection							
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample					=	33.3	19 - mg/L	01/30 - Monthly	CP - Composite					
					Permit Req.							Req Mon DAILY MX		0	01/30 - Monthly	CP - Composite			
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	2.67	19 - mg/L	01/07 - Weekly	CP - Composite					
					Permit Req.							Req Mon MO AVG		0	01/07 - Weekly	CP - Composite			
					Value NODI														
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample					=	4.73	19 - mg/L	01/30 - Monthly	CP - Composite					
					Permit Req.							Req Mon DAILY MX		0	01/30 - Monthly	CP - Composite			
					Value NODI														
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample					=	175.0	19 - mg/L	01/30 - Monthly	GR - Grab					
					Permit Req.							Req Mon DAILY MX		0	01/30 - Monthly	GR - Grab			
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	15.26	=	35.7					99/99 - Continuous					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX					0	99/99 - Continuous				
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	0.0	19 - mg/L	CL/OC - Chlorination/Occurances	GR - Grab					
					Permit Req.							<=	0.038 DAILY MX		0	CL/OC - Chlorination/Occurances	GR - Grab		
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	809.56	=	2277.55	=	26 - lb/d	19 - mg/L	02/DA - 2 Days Every Week	CP - Composite					
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	<=	26 - lb/d	<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**GLENBARD WASTEWATER AUTHORITY**

User: MAMCGRATH  
Name: Micaela McGrath  
E-Mail: mmcgrath@gbww.org  
Date/Time: 2026-04-17 08:56 (Time Zone: -05:00)

**Report Last Signed By**

User: MAMCGRATH  
Name: Micaela McGrath  
E-Mail: mmcgrath@gbww.org  
Date/Time: 2026-04-17 08:58 (Time Zone: -05:00)