

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:
Major:

IL0021547
Yes

Permittee:
Permittee Address:

GLENBARD WASTEWATER AUTHORITY
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Facility:
Facility Location:

GLENBARD WASTEWATER AUTHORITY - MAIN WWTP
945 BEMIS ROAD
GLEN ELLYN, IL 60137

Permitted Feature:

INF
Influent Structure

Discharge:

INF-L
INFLUENT MONITORING

Report Dates & Status

Monitoring Period:

From 08/01/26 to 08/31/26

DMR Due Date:

09/25/26

Status:

NetDMR Validated

Considerations for Form Completion

W0430600002

Principal Executive Officer

First Name:
Last Name:

Matt
Streicher

Title:

Executive Director

Telephone:

630-790-1901

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample							=		115.82			19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite
					Permit Req.									Req Mon MO AVG			19 - mg/L		02/DA - 2 Days Every Week	CP - Composite
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample							=		145.17			19 - mg/L	0	02/DA - 2 Days Every Week	CP - Composite
					Permit Req.									Req Mon MO AVG			19 - mg/L		02/DA - 2 Days Every Week	CP - Composite
					Value NODI															
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample										=	22.8	19 - mg/L	0	01/30 - Monthly	CP - Composite
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite
					Value NODI															
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample										=	5.78	19 - mg/L	0	01/30 - Monthly	CP - Composite
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	15.18	=	32.22	03 - MGD								0	99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User:

MAMCGRATH

Name:

Micaela McGrath

E-Mail:

mmcgrath@gbww.org

Date/Time:	2026-09-18 12:06 (Time Zone: -05:00)
<i>Report Last Signed By</i>	
User:	MAMCGRATH
Name:	Micaela McGrath
E-Mail:	mmcgrath@gbww.org
Date/Time:	2026-09-18 12:06 (Time Zone: -05:00)